ELECTRICAL PERMIT APPLICATION

CITY OF RENTON

Development Services Division 1055 South Grady Way, Renton WA 98057 Phone: (425) 430-7200 www.rentonwa.gov

ALL REQUESTED ITEMS MUST BE PROVIDED IN ORDER TO PROCESS THIS APPLICATION

1.	Property Address:			
2.	Building Permit # (Required):	3. Boeing Job # (if applicable):		
4.	Value* of Work to be Performed:			
5.	Type of Work to be Performed:			
6.	Minimum fee for remodel/addition of new	Other: Pools Signs Mobile Job Tr each eaximum of \$45.00)	& Hot Tubs Homes ailers	\$45.00 \$60.00 \$45.00 \$45.00 \$45.00
<u>Multi-</u>	circuits without a service change \$45.00 Reinspection Fee ulti-Family, Commercial and Industrial (based on value of work):			
	\$ 1.00 - \$ 250.00 - \$ 45.00 \$ 250.01 - \$ 1,000.00 - \$ 45.00 \$ 1,000.01 - \$ 5,000.00 - \$ 78.00 \$ 5,000.01 - \$ 50,000.00 - \$ 223.00 \$ 50,000.01 - \$ 250,000.00 - \$ 1,073.00 \$ 250,000.01 - \$1,000,000.00 - \$ 3,573.00 \$ 1,000,000.01 and up - \$ 11,573.00	+ 1.0% of value* + 0.8% of value*	of standard feet Plan Review Feet required shall be standard fee.	e – when
7.	Property Owner:		Phone:	
	Street Address:	City/State:	Zip:	
8.	Tenant Name (if applicable):		Suite/Room #:	
9.	Contractor:		Phone:	
	Street Address:	City/State:	Zip:	<u> </u>
10.	State of Washington Contractor's License #	(Required):		
service dwelling electric be done	Contractor's City of Renton Business Licens etallic sheathed cable shall be allowed only in residential of shall be underground except for existing residential dwelling moved to a new location. This application does not constal permit is posted on premises where work is to be performed except as described, and that all work shall conform to the assements is not authorized under this application.	ccupancies up to three s ngs. Underground service titute a permit to work. \ med. Certification is her	ce will be required on a Work is not to commen eby rendered that no v	any ice until vork is to
Applicant Signature: Date:				

GROUNDING ELECTRODE SYSTEM

Concrete-Encased Electrode: An electrode encased by at least two (2) inches (20.8 mm) of concrete, located within and near the bottom of a concrete footing that is in direct contact with the earth, consisting of at least 20 feet (6.1 m) of bare copper, sized in accordance with Table 250-66, 1999 NEC, shall be installed in all new residential and commercial construction.

CONCRETE ENCASED ELECTRODES SHALL BE INSTALLED IN ALL NEW RESIDENTIAL AND COMMERCIAL CONSTRUCTION INSTALLATIONS.

Alternative Approved Method:

An electrode consisting of 20 ft (6.1m) long, #4 rebar (not less than ½ inch in diameter meeting the requirements of NEC 250.52)) encased by at least 2 inches (20.8 mm) of concrete, located within and near the bottom of a concrete footing that is in direct contact with the earth. Sections of reinforcing bar are permitted to be tied together to make up the 20 foot length. Electrode splices shall overlap a minimum of 3 feet and be tied together at a minimum of 6 inches on center.

The electrode shall be stubbed up vertically a minimum of 1 foot above the top of the foundation wall adjacent to the service location. Service stubs shall be identified with orange fluorescent paint. Connection from the vertical section of the electrode to the service ground shall be made with a direct burial clamp to a minimum of a #4 copper conductor and made accessible.

The grounding electrode system inspection will be conducted with the footing inspection prior to placement of concrete.